

Disaster Risk Reduction Report

ACU WASH team has conducted a comprehensive related cholera WASH surveillance in Salama village based on the information provided by **EWARN team** which proves the increase in the number of cholera cases.

1. Location

Governorate	District	Sub-district	Community	Community	Community code
Aleppo	A'zaz	A'zaz	السلامة	Salama	C1561

2. Key findings

- This village is located in the A'zaz sub-district and was supplied with drinking water from the nearby station "Yazi Bagh" (Code of the station A050200801), which was operational and capable of pumping water to most people there, but this station has stopped a while ago, which forced the residents to rely on unsafe private wells to secure their needs of water.
- There is a sewage network in the village, which is in a medium technical status where it needs some rehabilitation in some parts in addition to an extension to cover the rest parts of the village where there is no sewage network. Some people there depend on septic tanks to drain the wastewater which is mostly open or covered by a metal sheet.



- There is an open line to drain rainwater and wastewater pass at the east part of the village and near the people's houses, as it constitutes a hotbed of pollution and a conducive environment for the growth of insects, mosquitoes and rodents, and harmful animals.

